

The logo for Fischer, featuring the word "fischer" in a bold, lowercase sans-serif font, followed by a small icon of a fish inside a circle.

## Examination Certificate

inspection order 20200238-2

for

***fischerwerke GmbH & Co. KG***

*Klaus-Fischer-Str. 1  
72178 Waldachtal  
Germany*

### Product description:

Test specimens: concrete screws  
Designation: FBS II CP 14 x 125  
Coating: fischer "corrosion protection" coating

### Test conditions:

- 2016 hrs. salt spray test to DIN EN ISO 9227 NSS:2017

### Test methods:

- Accredited test methods to DIN EN ISO/IEC 17025:2005

### Test result:

- The fischer corrosion protection coating of the "FBS II CP 14 x 125" concrete screws met the requirements for the salt spray test for the following classification "C3 very high" in accordance with DIN EN ISO 12944-6:2018.

Solingen, dated 13<sup>th</sup> October 2020  
IGOS GmbH & Co. KG

Dipl.-Ing. Josef Andrek  
Managing Director

Sarah Nieder  
Technician Electroplater

[www.igos.de](http://www.igos.de) · [info@igos.de](mailto:info@igos.de)

Beratung  
Galvanotechnik  
Korrosionsprüfung  
Chemische Analysen  
Schadensanalysen  
Schichtanalysen  
Gutachten  
Schulung